



**London Underground**  
Infrastructure Protection

3<sup>rd</sup> Floor  
Albany House  
55 Broadway  
London SW1H 0BD

[www.tfl.gov.uk/tube](http://www.tfl.gov.uk/tube)

Your ref: EPF/2115/18  
Our ref: 24211-SI-C024

David Baker  
Planning and Economic Development  
[appcomment@eppingforestdc.gov.uk](mailto:appcomment@eppingforestdc.gov.uk)

29 August 2018

Dear David,

**13-15a Alderton Hill Loughton IG10 3JD**

Thank you for your communication of 15<sup>th</sup> August 2018.

Though we have no objection in principle to the above planning application there are a number of potential constraints on the redevelopment of a site situated close to railway infrastructure. Therefore, it will need to be demonstrated to the satisfaction of LUL engineers that:

- our right of support is not compromised
- the development will not have any detrimental effect on our structures either in the short or long term
- the design must be such that the loading imposed on our structures is not increased or removed
- we offer no right of support to the development or land

Therefore we request that the grant of planning permission be subject to conditions to secure the following:

The development hereby permitted shall not be commenced until detailed design and method statements (in consultation with London Underground) for all of the foundations, basement and ground floor structures, or for any other structures below ground level, including piling (temporary and permanent), have been submitted to and approved in writing by the local planning authority which:

- provide details on all structures
- provide details on the use of tall plant/scaffolding
- accommodate the location of the existing London Underground structures
- there should be no opening windows or balconies facing the LU elevation

London Underground Limited  
trading as London Underground  
whose registered office is  
55 Broadway  
London SW1H 0BD

Registered in England and Wales  
Company number 1900907

VAT number 238 7244 46

London Underground Limited is  
a company controlled by a local  
authority within the meaning of  
Part V Local Government and  
Housing Act 1989. The controlling  
authority is Transport for London.

- demonstrate access to elevations of the building adjacent to the property boundary with London Underground can be undertaken without recourse to entering our land
- demonstrate that there will at no time be any potential security risk to our railway, property or structures
- accommodate ground movement arising from the construction thereof
- mitigate the effects of noise and vibration arising from the adjoining operations within the structures

The development shall thereafter be carried out in all respects in accordance with the approved design and method statements, and all structures and works comprised within the development hereby permitted which are required by the approved design statements in order to procure the matters mentioned in paragraphs of this condition shall be completed, in their entirety, before any part of the building hereby permitted is occupied.

**Reason:** To ensure that the development does not impact on existing London Underground transport infrastructure, in accordance with London Plan 2015 Table 6.1, draft London Plan policy T3 and 'Land for Industry and Transport' Supplementary Planning Guidance 2012.

We also ask that the following informative is added:

The applicant is advised to contact London Underground Infrastructure Protection in advance of preparation of final design and associated method statements, in particular with regard to: demolition; drainage; excavation; construction methods; tall plant: scaffolding: security; boundary treatment; safety barriers; landscaping and lighting

If I can be of further assistance, please contact me.

Yours sincerely

**Shahina Inayathusein**

Information Manager

Email: [locationenquiries@tube.tfl.gov.uk](mailto:locationenquiries@tube.tfl.gov.uk)

Direct line: 020 3054 1365